

**VIOLATION NOTICE**

CITY OF PHILADELPHIA

DEPARTMENT OF LICENSES & INSPECTIONS

PUBLIC SERVICE CONCOURSE

MUNICIPAL SERVICES BUILDING, PHILADELPHIA, PA. 19107

April 11, 1989

PREMISES
IN
VIOLATION

32687

48 - 60 Laurel Street

E-Z Chemical Co., Inc
c/o Ed. Zakrocki, Jr
48 - 60 Laurel Street
Philadelphia, PA 19123**RE-INSPECT ON**
APR 13 1989

An inspection of the above premises reveals conditions which are in violation of the Philadelphia Code of General Ordinances, as specified below. Your name appears on official records as the owner, agent or other responsible party for the premises found to be in violation. Failure to correct these conditions within the specified time of this notice will result in prosecution. If title has been transferred please furnish proof of transfer to L & I Central Clerical, Public Service Concourse, Municipal Services Building, 15th Street & J. F. Kennedy Boulevard, Philadelphia, Pa. 19107. The Department does not authorize anyone to solicit any work for services which may be required by this notice.

Violations which do not have a specific location shown apply to the entire premises.

For information on the violations, contact:

Ste. 600, One Reading Center, 1101 Market St. 592-6067

A REINSPECTION WILL BE MADE IMMEDIATELY.**INSPECTOR: LEBOWITZ**

Report any violation on this notice apply to the Board of License and Inspection Review, Room 710 Municipal Services Building, Philadelphia, Pa. 19107 within 10 days of this notice. It is required to submit a copy of this notice with the appeal.

SECTION

VIOLATION

"Appeals from Fire Code violation should be directed to the Board of Safety and Fire Prevention within 30 days of the date of this notice on forms provided by that Board. The forms can be acquired by visiting, or writing the District Office listed in this notice."

- | | | |
|--------------|-----|---|
| 5-504(3) | 500 | Remove all defective containers and spilled material (yard) |
| 5-3102(2) | 43 | Remove waste, litter, rubbish and weeds from property
remove all waste & debris from property |
| 5-1609(2)(A) | 913 | Provide volumetric capacity of all dike area N.F.P.A. 30. |
| 5-1609 (2) | 905 | Repair or replace defective or leaking piping immediately. |
| 5-1609(2)(a) | 906 | Remove all flammable liquid at base of tank. NFPA 30. |
| 5-1403(1) | 910 | Correct condition causing water to accumulate so that ice cannot form and hamper operation of flammable liquid control valve. |
| 5-503(4) | 119 | Store hazardous chemicals in dry places
Large tank used to store hazardous chemicals - flooded |
| 5-3109 | 501 | Provide access for Fire Dept. vehicles |
| 5-505 | 503 | Provide separation of acid storage and flammable liquid storage
Yard and building |

Cont

100073